

## BUSINESS SELF INSPECTION FORM

Provided courtesy of the Euless Fire Department

1. Is building free of debris?  
from floor level to above the panel box?.
2. Is the dumpster a minimum of six feet from the building?
3. Is your address posted in numbers at least 8 inches tall and clearly visible from the street?
4. Are No Smoking signs posted in appropriate areas?
5. Are smoking areas designated?
6. Are persons smoking only in designated areas?
7. Are floors clear of cigarette butts?
8. Are electrical outlets in good repair?
9. Are all electrical outlet cover plates in place and in good repair?
10. Are all electrical cords in good condition and not running through doorways or otherwise located where they could be damaged?
11. Are electrical extension cords overloaded, attached to the walls or used in place of permanent wiring?
12. Are electrical panel boxes easily accessible with no storage within a 30 inch arc measured from the center of the box and ranging
13. Does all electrical equipment appear to be in good condition?
14. Are all heaters and similar heat producing products kept away from combustibles? A recommended distance is 36 inches minimum between combustibles and a heat source as a good rule of thumb.
15. Are all exit lights operating?
16. Are all exit doors unlocked and open easily?
17. Are all exit paths clear of storage or debris?
18. Are fire extinguisher(s) visible?
19. Does the gauge on the fire extinguisher show the extinguisher is full?
20. Are all fire alarm panels, sprinkler control valves and extinguishers have a tag attached showing a licensed service company inspected them within the past year?

The Euless Fire Marshals Office provides this document as a courtesy. **If you answer any question with a "No", an apparent problem exists.**

If you require any assistance or wish to schedule an inspection, please call 817-685-1600.

