



# Texas Department of Insurance

State Fire Marshal's Office, Mail Code 112-FM  
 333 Guadalupe • P. O. Box 149221, Austin, Texas 78714-9221  
 512-305-7900 • 512-305-7910 fax • www.tdi.state.tx.us

## PPC SUBMITTAL

Municipality	<u>Eules</u>	County	<u>Tarrant</u>	Population	<u>53400</u>
Date Surveyed	<u>12/18/2007</u>	Total Credit	<u>94.36</u>	Class	<u>1</u>
Date Submitted	<u>09/02/2008</u>	Effective Date	<u>02/01/2009</u>		
Place Code	<u>43918</u>	Addendum Applied	<u>12/18/2007</u>		

## SUMMARY OF CREDIT

<u>Feature</u>	<u>Assigned Credit</u>		<u>Maximum Credit</u>
Receiving and Handling Fire Alarms	9.37		10.00%
Water Supply	39.05	Total:FD/CTT	40.00
Fire Department	42.13	42.40	50.00
Texas State Training (CTT)	0.27	Total:CTT/CTX	3.26
Texas Addendum Credit (CTX)	6.11	6.38	6.50
* Divergence	<u>&lt; 2.57 &gt;</u>		
Total Points	94.36		106.50

The Public Protection Class is based on the total percentage credit as follows:

<u>Class</u>	<u>Percentage %</u>
1	90.00 or more
2	80.00 to 89.99
3	70.00 to 79.99
4	60.00 to 69.99
5	50.00 to 59.99
6	40.00 to 49.99
7	30.00 to 39.99
8	20.00 to 29.99
9	10.00 to 19.99
10	0 to 9.99

TEXAS DEPARTMENT OF INSURANCE

Approved

SEP 11 2008

State Fire Marshal

\* Divergence is a reduction in credit to reflect a difference in the relative credits for the Fire Department and Water Supply.

The difference between the protection provided by the fire department and the water supply prevents the better feature from being utilized to its fullest extent. Therefore, an adjustment (divergence) is made to reflect any difference between these two features. Because of the difference in the total weights assigned to the two features, the total for the Fire Department, which has the higher total weight, is adjusted to make the comparison reflect the relative adequacies of the two features.

Divergence = 50% (100% water supply credit – 80% of fire department credit)