



Texas Department of Insurance State Fire Marshal's Office

Mail Code 112-FM, 333 Guadalupe • P.O. Box 149221, Austin, Texas 78714-9104
512-676-6800 telephone • 512-490-1063 fax • www.tdi.texas.gov

PPC SUBMITTAL

| | | | | | |
|---------------|------------|-------------------|------------|-------------|-------|
| Municipality: | Eules | County: | Tarrant | Population: | 54250 |
| Surveyed: | 12/13/2016 | Total Credit: | 99.20 | | 01 |
| Submitted: | 04/03/2017 | Effective Date: | 09/01/2017 | | |
| Place Code: | 43918 | Addendum Applied: | 12/13/2016 | | |

SUMMARY OF ASSIGNED CREDIT

| Feature | Assigned Credit | Addendum Credit | Maximum Credit Texas |
|-------------------------------|-----------------|-----------------|-------------------------|
| Emergency Communications | 9.85 | | 10.00 |
| Water Supply | 39.20 | | 40.00 |
| Fire Department | 45.26 | | 50.00 |
| Texas State Training (CTT) | | 0.00 | 3.26 |
| FSRS Community Risk Reduction | | 5.39 | 5.50 |
| Texas Addendum Credit (CAFS) | | 1.00 | 1.00 |
| * Divergence: | < 1.50 > | | |
| Total Points: | 92.81 | 6.39 | 109.76 |

The Public Protection Class is based on the total percentage credit as follows:

Texas Department of Insurance
Approved by

Chris Combs

APR 10 2017

State Fire Marshal

| Class | Percentage % |
|-------|----------------|
| 1 | 90.00 or more |
| 2 | 80.00 to 89.99 |
| 3 | 70.00 to 79.99 |
| 4 | 60.00 to 69.99 |
| 5 | 50.00 to 59.99 |
| 6 | 40.00 to 49.99 |
| 7 | 30.00 to 39.99 |
| 8 | 20.00 to 29.99 |
| 9 | 10.00 to 19.99 |
| 10 | 0 to 9.99 |

Divergence is a reduction in credit to reflect a difference in the relative credits for the Fire Department and Water Supply.

The difference in protection provided by the fire department and the water supply prevents the better feature from being utilized to its fullest extent. Therefore, an adjustment (divergence) is made to reflect any difference between these two features. Because of the difference in the total weights assigned to the two features, the total for the Fire Department is adjusted to make the comparison reflect the relative adequacies of the two features.

Divergence = 50% (100% water supply credit – 80% of fire department credit)