



2016 Annual Water Quality Report

Consumer Confidence Report

(817) 685-1581 | www.EulessTx.gov/Water

Este reporte incluye informacion importante sobre el agua para tomar. Si tiene preguntas o discusiones sobre este reporte en espanol, favor de llamar al tel. (817) 685-1584 para hablar con una persona bilingue en espanol.

Our Drinking Water Meets or Exceeds All Federal (EPA) Drinking Water Requirements

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. The City of Euless is a member of the American Water Works Association and the Texas Water Utilities Association.

Public Participation Opportunities:

We encourage public interest and participation in our community's decisions affecting drinking water. Regular City Council meetings take place on the second & fourth Tuesdays of the month, at 7 p.m. in Euless City Hall, 201 N. Ector Dr. The public is welcome. (817) 685-1400.

Water Sources:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil & gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

Special Notice

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline.

Required Additional Health Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Where do we get our Drinking Water?

Our drinking water is obtained from surface and ground water sources. It is supplied by Trinity River Authority (Cedar Creek and Richland Chambers Lakes) and Euless water wells (Trinity Aquifer). A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus source water protection strategies.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL: <http://www.tceq.texas.gov/gis/swaview>. Further details about sources and source-water assessments are available at <http://dww.tceq.state.tx.us/DWW>.

Coliform Bacteria						
MCLG	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli MCL	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	5% of monthly samples are positive.	0.0 percent of samples were positive		0	N	Naturally present in the environment.

Lead and Copper								
Lead and Copper	Date Sampled	MCLG	The 90 th Percentile	Action Level	Site # Over Action Level	Units	Violation	Likely Source of Contamination
Copper	7/7/2015	1.3	0.227	1.3	0	Ppm	No	Erosion of natural deposits; Corrosion of household plumbing systems.
Lead	6/30/2015	0	1.41	15	0	ppb	No	Corrosion of plumbing systems; Erosion of natural deposits.

Regulated Contaminants									
Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination	
Acetone	4/5/2016	.005	.005-.005	0	0	ppb	No	By-product of drinking water disinfection	
Arsenic	1/3/2016	0.07	.07-.07	0	10	ppb	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass & electronics production wastes.	
Antimony (Total)	4/5/2016	.001	.001-.001	.006	.006	ppb	No	Naturally occurring element	
Atrazine	4/5/2016	0.08	0.08 - 0.08	3	3	ppb	No	Runoff from herbicide used on row crops.	
Barium	3/1/2016	TRA	0.039	0.039 - 0.039	2	2	ppm	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
		Eules	0.05	0.051 - 0.051					
Bromate	2016	12	<5 - 12	0	10*	ppb	No	By-product of drinking water disinfection	

*Compliance is based on Running Annual Average of monthly averages for Bromate at the end of each quarter, which was less than 5 ppb for each quarter in 2016.

Chromium	3/1/2016	TRA	82	82-82	100	100	ppb	No	Naturally occurring element
	4/5/2016	Eules	0.004	0.004-0.004	100	100	ppb	No	
Cyanide	3/1/2016	TRA	25.9	25.9 - 25.9	200	200	ppb	No	Discharge from steel/metal factories; Discharge from plastic and fertilizer factories.
		Eules	7.1	7.1-7.1					
Fluoride	3/1/2016	TRA	0.69	0.69 - 0.69	4	4	ppb	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer & aluminum factories.
		Eules	1.87	1.87 - 1.87					
Nitrate (measured as Nitrogen)	3/1/2016	TRA	0.45	0.45 - 0.45	10	10	ppm	No	Runoff from fertilizer use; Leaching from septic tanks; Sewage; Erosion of natural deposits.
		Eules	10	0 - 10					
Nitrite (measured as Nitrogen)	2016		4	1 - 4	10	1000	ppm	No	Runoff from fertilizer use; Leaching from septic tanks, sewage, erosion of natural deposits.
Simazine	2016		0.05	0.05 - 0.05	4	4	ppm	No	Herbicide runoff.
Total Organic Carbon (TOC) Removal ratio*	2016		1.49	1.00 - 1.49	None	TT=1.0	None	No	Naturally present in the environment.
Zinc	2016		.002	.002-.002	5	5	Mg/l	No	Naturally occurring element

*Removal ratio is the percent TOC removed by the treatment process divided by the percent of TOC removal required by TCEQ.

Turbidity highest single measurement	2016		0.19	0.11 - 0.19	0	TT=1.0	NTU	No	Soil runoff. Good indicator of water quality & filtration.
% of samples ≤ 0.3 NTU	2016		Lowest was 100	100 - 100	100	TT=95	%	No	
Haloacetic Acids (HAA5*)	2016	TRA	20	19.5 - 19.5	No goal	60	ppb	No	By-product of drinking water chlorination.
		Eules	29.2	0 - 33.1					
Total Trihalomethanes	2016	TRA	55	54.9 - 54.9	No goal	80	ppb	No	By-product of drinking water chlorination.
		Eules	58	1 - 58					

Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future.

Unregulated Contaminants						
Contaminant	Collection Date	Average	Range of Levels Detected	Units	Violation	Likely Source of Contamination
Bromodichloromethane	2016	15.3	13.6-13.6	ppb		By-product of drinking water chlorination.
Chloroform	2016	13.6	10.1-10.1	ppb		By-product of drinking water chlorination.
Dibromochloromethane	2016	7.94	7.94-7.94	ppb		By-product of drinking water chlorination.

Radionuclides								
Contaminant	Collection Date	Highest Single Sample	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/Photon emitters	1/22/2015	4.6	4.6 - 4.6	0*	50*	pCi/L	No	Decay of natural and man-made deposits.

*MCLG and MCL are given in exposure units of millirem/year (set at 0 and 4, respectively), but samples are measured in activity units of pico Curies/Liter (pCi/L). EPA considers 50 pCi/L to be the level of concern for Beta particles.

Secondary and Other Constituents Not Regulated							
Contaminant	Collection Date	Highest	Range of Levels Detected	Secondary Limit	Units	Violation	Likely Source of Contamination
Aluminum	3/8/2016	43	43-43	200	ppb	No	Abundant naturally occurring element.
Bicarbonate [as Calcium carbonate]	3/1/2016	94	94 - 94	None	ppm	No	Erosion of carbonate rocks such as limestone.
Calcium	3/1/2016	41.8	41.8-41.8	None	ppm	No	Abundant naturally occurring element.
Chloride	3/1/2016	17.1	17.1 - 17.1	300	ppm	No	Abundant naturally occurring element. Used in water purification; By-product of oil field activity.
Conductivity @ 25°C	3/1/2016	383	383 - 383	None	µhms/cm	No	Ability of water to conduct electricity due to electrolytes.
Copper	3/1/2016	31	31 - 31	1000*	ppb	No	Erosion of natural deposits; Corrosion of household plumbing.

*This secondary limit is for Copper as a nuisance contaminant, apart from the primary list because it can stain fixtures and impart a bitter metallic taste to drinking water.

Magnesium	3/1/2016	4.40	4.40 - 4.40	None	ppm	No	Abundant naturally occurring element.
Manganese	3/1/2016	14.0	14 - 14	50	ppb	No	Naturally occurring element.
Nickel	3/1/2016	0.85	0.85 - 0.85	None	ppb	No	Naturally occurring element.
Potassium	3/1/2016	3.76	3.76 - 3.76	None	ppm	No	Naturally occurring element.
pH	2016	8.7	7.0 - 8.7	>7.0	pH unit	No	Measure of the corrosivity of water.
Sodium	3/1/2016	25.2	25.2 - 25.2	None	ppm	No	Abundant naturally occurring element. By-product of oil field activity.
Silver	4/5/2016	.04	.04 - .04	100	ppb	No	Naturally occurring element.
Sulfate	3/1/2016	51.3	51.3 - 51.3	300	ppm	No	Naturally occurring constituent; Common industrial by-product; By-product of oil field activity.

Total Alkalinity [as Calcium carbonate]	3/1/2016	94	94 - 94	None	ppm	No	Naturally occurring soluble mineral salts.
Total Dissolved Solids	1/22/2015	893	893-893	1000	ppm	No	Total dissolved mineral constituents in water.
Total Hardness [as Calcium carbonate]	3/1/2016	123	123 - 123	None	ppm	No	Naturally occurring soluble Calcium and Magnesium deposits.

Maximum Residual Disinfectant Level									
Year or Range	Disinfectant	Avg. Level	Min. Level	Max. Level	MRDL	MRDLG	Measurement	Violation	Source of Contaminant
2016	Chlorine Residual, Free	2.13	0.5	4	4	4	ppm	No	Disinfectant used to control microbes.